

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 5620-1422:100

Page 1 of 1

**CATEGORY:** Tubing/Conduit

**LISTEE:** Alfex Corporation, 2630 El Presidio Street, Long Beach, CA 90810  
Contact: Richard Temblador (310) 886-8300

**DESIGN:** ALFLEX aluminum and \*steel flexible conduits. The aluminum conduit in trade sizes of 1/2", 3/4", 1", 1-1/4", 1-1/2", and 2". The steel conduit in trade sizes of 5/16", 3/8", 1/2", 3/4", 1", and 1-1/4". Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, size and UL label.

**APPROVAL:** Listed as aluminum and steel flexible conduits for use in fire-resistive assemblies.

**NOTE:** Formerly 6610-1422:100

\*Rev. 03-01-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MARCH 18, 2002**

**Listing Expires June 30, 2002**

Authorized By:

**DIANE K. AREND, Senior Deputy  
Program Manager**